



# Life Science Laboratories, Inc.

## Laboratory Analysis Report Prepared For Salmon River Central School

LSL Project ID: 1617852

Glen Johnson  
Salmon River Central School  
637 Cty. Rt. #1  
Fort Covington, NY 12937

Phone: (518) 358-6690  
FAX: (518) 358-3492  
Authorization: PO #030468  
Fed. Water Supply ID: NY1602611

*A copy of this report was sent to: Saranac Lake District Office  
NYS Department of Health*

Sample ID: Lead Study	LSL Sample ID: 1617852-001			
Location:	Receive Date/Time: 10/26/16 8:39			
Sampled: 10/21/16 0:00	Source Code: Reason Code: Project Rec'd by: CAB			
Sampled By: Client	Matrix: PWS			
Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study

Number of Samples	21	MT
-------------------	----	----

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab 5854 Butternut Drive East Syracuse, NY 13057 Tel. (315) 445-1900 Fax (315) 445-1104 NYS DOH ELAP #10248 PA DEP #68-2556	LSL North Lab 131 St. Lawrence Avenue Waddington, NY 13694 Tel. (315) 388-4476 Fax (315) 388-4061 NYS DOH ELAP #10900	LSL Finger Lakes Lab 16 N. Main St., PO Box 424 Wayland, NY 14572 Tel. (585) 728-3320 Fax (585) 728-2711 NYS DOH ELAP #11667	LSL Southern Tier Office Cuba, NY Tel. (585) 209-4032  LSL MidLakes Office Canandaigua, NY Tel. (585) 728-3320
---	--	---	--

Reviewed by:

Date:

11/17/16

David J. Prichard, Director of Tech. Services

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-1

**Lab ID:** K1611106-001A  
**Collection Date:** 10/21/16 5:24  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0029	mg/L	11/14/16 18:31

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-2

**Lab ID:** K1611106-002A  
**Collection Date:** 10/21/16 5:31  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0060	mg/L	11/14/16 18:35

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-3

**Lab ID:** K1611106-003A  
**Collection Date:** 10/21/16 5:35  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/14/16 18:38

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-4

**Lab ID:** K1611106-004A  
**Collection Date:** 10/21/16 5:36  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0012	mg/L	11/14/16 18:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-5

**Lab ID:** K1611106-005A  
**Collection Date:** 10/21/16 5:40  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.023 *	mg/L	11/14/16 18:46

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-6

**Lab ID:** K1611106-006A  
**Collection Date:** 10/21/16 5:46  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0018	mg/L	11/14/16 18:50

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-7

**Lab ID:** K1611106-007A  
**Collection Date:** 10/21/16 5:52  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0040	mg/L	11/14/16 18:54

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-8

**Lab ID:** K1611106-008A  
**Collection Date:** 10/21/16 5:52  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0071	mg/L	11/14/16 18:57

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-9

**Lab ID:** K1611106-009A  
**Collection Date:** 10/21/16 5:57  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.015	mg/L	11/14/16 19:01

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-10

**Lab ID:** K1611106-010A  
**Collection Date:** 10/21/16 6:02  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/14/16 19:05

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-11

**Lab ID:** K1611106-011A  
**Collection Date:** 10/21/16 6:02  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/14/16 19:16

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-12  
**Lab ID:** K1611106-012A  
**Collection Date:** 10/21/16 6:10  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.046 *	mg/L	11/14/16 19:20

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-13

**Lab ID:** K1611106-013A  
**Collection Date:** 10/21/16 6:18  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.024 *	mg/L	11/14/16 19:24

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-14

**Lab ID:** K1611106-014A  
**Collection Date:** 10/21/16 6:19  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.022 *	mg/L	11/14/16 19:27

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-15  
**Lab ID:** K1611106-015A  
**Collection Date:** 10/21/16 6:21  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.044 *	mg/L	11/14/16 19:31

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-16  
**Lab ID:** K1611106-016A  
**Collection Date:** 10/21/16 6:26  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.035 *	EPA 200.8 mg/L	(EPA 200.2) 11/14/16 19:35

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-17  
**Lab ID:** K1611106-017A  
**Collection Date:** 10/21/16 6:30  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.11 *	mg/L	11/14/16 19:39

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-18  
**Lab ID:** K1611106-018A  
**Collection Date:** 10/21/16 6:34  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.17 *	mg/L	11/15/16 15:58

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-19  
**Lab ID:** K1611106-019A  
**Collection Date:** 10/21/16 6:36  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.053 *	mg/L	11/14/16 20:01

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-20

**Lab ID:** K1611106-020A  
**Collection Date:** 10/21/16 6:38  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.024 *	mg/L	11/14/16 20:05

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617852-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC2-21  
**Lab ID:** K1611106-021A  
**Collection Date:** 10/21/16 6:45  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.028 *	mg/L	11/14/16 20:09

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-1  
**Lab ID:** K1611107-001A  
**Collection Date:** 10/21/16 5:28  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0021	EPA 200.8 mg/L	(EPA 200.2) 11/14/16 16:23

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS **Client Sample ID:** SRC1-2  
**Project:** 1617853-Salmon River Central School  
**Location:** **Lab ID:** K1611107-002A  
**Matrix:** PW **Collection Date:** 10/21/16 5:32  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0011	mg/L	11/14/16 16:34

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-3  
**Lab ID:** K1611107-003A  
**Collection Date:** 10/21/16 5:31  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0012	mg/L	11/14/16 16:38

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-4  
**Lab ID:** K1611107-004A  
**Collection Date:** 10/21/16 5:31  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0023	mg/L	11/14/16 16:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-5  
**Lab ID:** K1611107-005A  
**Collection Date:** 10/21/16 5:35  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0012	mg/L	11/14/16 16:46

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-6  
**Lab ID:** K1611107-006A  
**Collection Date:** 10/21/16 5:36  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0016	mg/L	11/14/16 16:49

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-7  
**Lab ID:** K1611107-007A  
**Collection Date:** 10/21/16 5:37  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0059	mg/L	11/14/16 17:01

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-8  
**Lab ID:** K1611107-008A  
**Collection Date:** 10/21/16 0:00  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.020 *	mg/L	11/14/16 17:04

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-9  
**Lab ID:** K1611107-009A  
**Collection Date:** 10/21/16 5:50  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/14/16 17:08

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-10  
**Lab ID:** K1611107-010A  
**Collection Date:** 10/21/16 5:58  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0044	mg/L	11/14/16 17:12

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-11  
**Lab ID:** K1611107-011A  
**Collection Date:** 10/21/16 6:00  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0042	mg/L	11/14/16 17:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-12  
**Lab ID:** K1611107-012A  
**Collection Date:** 10/21/16 6:01  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.021 *	mg/L	11/14/16 17:19

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-13  
**Lab ID:** K1611107-013A  
**Collection Date:** 10/21/16 6:02  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/14/16 17:23

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-14  
**Lab ID:** K1611107-014A  
**Collection Date:** 10/21/16 6:04  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0014	mg/L	11/14/16 17:27

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-15  
**Lab ID:** K1611107-015A  
**Collection Date:** 10/21/16 6:09  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.027 *	mg/L	11/14/16 17:31

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-16  
**Lab ID:** K1611107-016A  
**Collection Date:** 10/21/16 6:10  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.032 *	mg/L	11/14/16 17:34

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-17  
**Lab ID:** K1611107-017A  
**Collection Date:** 10/21/16 6:11  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0080	mg/L	11/14/16 17:46

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS Client Sample ID: *SRC1-18*  
 Project: 1617853-Salmon River Central School  
 Location: Lab ID: **K1611107-018A**  
 Matrix: PW Collection Date: 10/21/16 6:25  
 Date Received: 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.012	mg/L	11/14/16 17:49

- Qualifiers:
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-19  
**Lab ID:** K1611107-019A  
**Collection Date:** 10/21/16 6:27  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0048	mg/L	11/14/16 17:53

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

## Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-20  
**Lab ID:** K1611107-020A  
**Collection Date:** 10/21/16 6:32  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.031 *	mg/L	11/14/16 17:57

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit
- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-21  
**Lab ID:** K1611107-021A  
**Collection Date:** 10/21/16 6:30  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.019 *	mg/L	11/14/16 18:01

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-22  
**Lab ID:** K1611107-022A  
**Collection Date:** 10/21/16 6:36  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(EPA 200.2)</b>
Lead	0.0013	mg/L	11/14/16 18:12

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive  
East Syracuse , NY 13057 (315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-23  
**Lab ID:** K1611107-023A  
**Collection Date:** 10/21/16 0:00  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.018 *	mg/L	11/14/16 18:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1617853-Salmon River Central School  
**Location:**  
**Matrix:** PW

**Client Sample ID:** SRC1-24

**Lab ID:** K1611107-024A  
**Collection Date:** 10/21/16 6:45  
**Date Received:** 10/26/16 8:39

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(EPA 200.2)
Lead	0.0058	mg/L	11/14/16 18:20

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits

# Life Science Laboratories, Inc.

## Sample Receipt Checklist

LSL LIMS

**Project ID**

1617853

**Client ID:** SalmonRiverCS

**Shipment Number** 1

**SRC Completed By:** njw2

**Date:** 11/22/2016 3:57:10 PM

<i>COC Date/Time</i>	<i>Received By</i>	<i>Carrier</i>	<i>ShippingID</i>
10/26/2016 8:39:00 AM	CAB	Hand Delivered	
<i>Shipping container/cooler in good condition?</i>	Yes	<i>Sample containers intact?</i>	Yes
<i>Custody seal intact on shipping container/cooler?</i>	N/A	<i>Sufficient sample volume for indicated test?</i>	Yes
<i>Custody seals intact on sample bottles?</i>	N/A	<i>All samples received within holding time?</i>	Yes
<i>Chain of Custody present?</i>	Yes	<i>Container/Temp Blank temperature in compliance?</i>	Yes
<i>COC signed when relinquished and received?</i>	No	<i>Water - VOA vials have zero headspace?</i>	N/A
<i>COC agrees with sample labels?</i>	Yes	<i>Water - pH acceptable upon receipt?</i>	N/A
<i>Samples in proper containers/bottles?</i>	Yes	<i>Water - HNO3 added to unpreserved metal sample(s) to a pH of &lt;2?</i>	Yes

**Comments:** Sample times were taken from the container labels.

**Corrective Action:**

**Reviewed By:** OK, 11/22/16