



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Salmon River

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 05/07/2021
Reported: 07/22/2021

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 89, Drinking Water, J1E1294-01, RF - Client, 05/06/2021 7:00.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.000814.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 86, Drinking Water, J1E1294-02, RF - Client, 05/06/2021 7:00.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.000610.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 229, Drinking Water, J1E1294-03, RF - Client, 05/06/2021 6:55.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <0.000400.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 71, Drinking Water, J1E1294-04, RF - Client, 05/06/2021 6:55.

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00104.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 91 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-05 | | Collection Date: 05/06/2021 7:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00100 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1724 | 07/02/21 1724 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 41B | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-06 | | Collection Date: 05/06/2021 7:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00200 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1731 | 07/02/21 1731 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 39 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-07 | | Collection Date: 05/06/2021 6:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0112 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1733 | 07/02/21 1733 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 69 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-08 | | Collection Date: 05/06/2021 6:59 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000925 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1735 | 07/02/21 1735 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 73 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-09 | | Collection Date: 05/06/2021 6:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00102 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1737 | 07/02/21 1737 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 93 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-10 | | Collection Date: 05/06/2021 7:02 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000834 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1738 | 07/02/21 1738 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 38 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-11 | | Collection Date: 05/06/2021 7:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00836 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1740 | 07/02/21 1740 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 37 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-12 | | Collection Date: 05/06/2021 7:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00953 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1748 | 07/02/21 1748 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 75 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-13 | | Collection Date: 05/06/2021 6:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000735 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1749 | 07/02/21 1749 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 203 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-14 | | Collection Date: 05/06/2021 7:06 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00256 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1757 | 07/02/21 1757 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 43b | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-15 | | Collection Date: 05/06/2021 7:17 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00144 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1759 | 07/02/21 1759 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 230 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-16 | | Collection Date: 05/06/2021 7:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0164 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1800 | 07/02/21 1800 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 41 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-17 | | Collection Date: 05/06/2021 6:12 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00608 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1802 | 07/02/21 1802 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 43A | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-18 | | Collection Date: 05/06/2021 7:17 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00140 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1804 | 07/02/21 1804 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 72 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-19 | | Collection Date: 05/06/2021 6:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00180 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1806 | 07/02/21 1806 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 51 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-21 | | Collection Date: 05/06/2021 6:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00271 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1808 | 07/02/21 1808 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 90 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-22 | | Collection Date: 05/06/2021 7:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00220 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1822 | 07/02/21 1822 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 70 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-23 | | Collection Date: 05/06/2021 6:52 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000965 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1828 | 07/02/21 1828 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 227 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-24 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000637 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1830 | 07/02/21 1830 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 220 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-25 | | Collection Date: 05/06/2021 6:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00167 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1833 | 07/02/21 1833 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 57a | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-26 | | Collection Date: 05/06/2021 6:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00142 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1835 | 07/02/21 1835 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 221 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-27 | | Collection Date: 05/06/2021 6:40 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00149 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1837 | 07/02/21 1837 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 224 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-28 | | Collection Date: 05/06/2021 6:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00129 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1839 | 07/02/21 1839 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 74 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-29 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000636 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1841 | 07/02/21 1841 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 225 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-30 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00160 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1848 | 07/02/21 1848 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 76 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-31 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00426 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1850 | 07/02/21 1850 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 228 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-32 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000907 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1852 | 07/02/21 1852 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 77 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-33 | | Collection Date: 05/06/2021 6:46 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00116 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1859 | 07/02/21 1859 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 78 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-34 | | Collection Date: 05/06/2021 6:46 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00143 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1901 | 07/02/21 1901 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 79 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-35 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000831 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1903 | 07/02/21 1903 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 226 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-36 | | Collection Date: 05/06/2021 6:40 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000646 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1904 | 07/02/21 1904 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 80 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-37 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000657 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1906 | 07/02/21 1906 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 81 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-38 | | Collection Date: 05/06/2021 6:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000903 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1914 | 07/02/21 1914 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 52 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-39 | | Collection Date: 05/06/2021 6:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000635 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1915 | 07/02/21 1915 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 53 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-40 | | Collection Date: 05/06/2021 6:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00219 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1917 | 07/02/21 1917 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 2 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-41 | | Collection Date: 05/06/2021 6:05 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00732 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1919 | 07/02/21 1919 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 4 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-42 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00625 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1928 | 07/02/21 1928 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 3 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-43 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00533 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1939 | 07/02/21 1939 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 7 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-44 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000487 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1941 | 07/02/21 1941 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 6 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-45 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00433 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1943 | 07/02/21 1943 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 8 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-46 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000536 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1945 | 07/02/21 1945 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 9 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-47 | | Collection Date: 05/06/2021 6:15 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1947 | 07/02/21 1947 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 5 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-48 | | Collection Date: 05/06/2021 6:10 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00320 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1950 | 07/02/21 1950 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 10 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-49 | | Collection Date: 05/06/2021 6:16 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0314 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1952 | 07/02/21 1952 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 63 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-50 | | Collection Date: 05/06/2021 6:26 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00161 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1954 | 07/02/21 1954 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 64 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-51 | | Collection Date: 05/06/2021 6:26 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000737 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1956 | 07/02/21 1956 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 65 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-52 | | Collection Date: 05/06/2021 6:27 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000594 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 1958 | 07/02/21 1958 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 56 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-53 | | Collection Date: 05/06/2021 6:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00117 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2009 | 07/02/21 2009 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 61 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-54 | | Collection Date: 05/06/2021 6:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000748 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2010 | 07/02/21 2010 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 55 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-55 | | Collection Date: 05/06/2021 6:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00119 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2012 | 07/02/21 2012 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 59 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-56 | | Collection Date: 05/06/2021 6:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000767 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2016 | 07/02/21 2016 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 60 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-57 | | Collection Date: 05/06/2021 6:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000638 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2018 | 07/02/21 2018 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 202 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-58 | | Collection Date: 05/06/2021 6:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|----------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | | 07/02/21 2020 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 57 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-59 | | Collection Date: 05/06/2021 6:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00180 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2021 | 07/02/21 2021 | SEA |

| | | |
|--|--------------------------------------|---|
| Client Sample ID: 22 (Bottle Labeled 222) | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-60 | | Collection Date: 05/06/2021 6:41 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00211 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2023 | 07/02/21 2023 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 133 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-61 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000902 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2030 | 07/02/21 2030 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 139 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-62 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00101 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2040 | 07/02/21 2040 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 138 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-63 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00173 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2047 | 07/02/21 2047 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 141 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-64 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00118 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2049 | 07/02/21 2049 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 142 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-65 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000627 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2051 | 07/02/21 2051 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 132 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-66 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00169 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2058 | 07/02/21 2058 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 144 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-67 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00282 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2100 | 07/02/21 2100 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 145 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-68 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000897 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2102 | 07/02/21 2102 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 165 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-69 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00142 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2103 | 07/02/21 2103 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 136 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-70 | | Collection Date: 05/06/2021 7:58 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000609 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1546 | 07/06/21 1546 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 130 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-71 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00152 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2109 | 07/02/21 2109 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 156 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-72 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00181 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2111 | 07/02/21 2111 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 153 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-73 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000887 | 0.015 AL | 0.000400 | mg/L | | 07/02/21 2116 | 07/02/21 2116 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 135 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-74 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00186 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1548 | 07/06/21 1548 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 157 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-75 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000836 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1549 | 07/06/21 1549 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 168 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-76 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00619 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1551 | 07/06/21 1551 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 154 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-77 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1555 | 07/06/21 1555 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 169 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-78 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00116 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1557 | 07/06/21 1557 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 166 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-79 | | Collection Date: 05/06/2021 8:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0119 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1559 | 07/06/21 1559 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 1 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-80 | | Collection Date: 05/06/2021 6:05 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00353 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1600 | 07/06/21 1600 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 46 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-81 | | Collection Date: 05/06/2021 7:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00577 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1608 | 07/06/21 1608 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 45 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-82 | | Collection Date: 05/06/2021 7:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0142 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1730 | 07/06/21 1730 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 46B | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-83 | | Collection Date: 05/06/2021 7:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0119 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1736 | 07/06/21 1736 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 48B | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-84 | | Collection Date: 05/06/2021 7:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|--------|----------|----------|-------|------|----------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.0128 | 0.015 AL | 0.000400 | mg/L | | | 07/06/21 1738 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 49A | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-85 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00228 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1741 | 07/06/21 1741 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 48 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-86 | | Collection Date: 05/06/2021 7:25 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00879 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1743 | 07/06/21 1743 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 50b | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-87 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000548 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1745 | 07/06/21 1745 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 49B | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-88 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00120 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1747 | 07/06/21 1747 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 50A | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-89 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000826 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1748 | 07/06/21 1748 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 47 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-90 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00758 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1756 | 07/06/21 1756 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 129 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-91 | | Collection Date: 05/06/2021 7:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00198 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1758 | 07/06/21 1758 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 33 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-92 | | Collection Date: 05/06/2021 7:40 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|----------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00512 | 0.015 AL | 0.000400 | mg/L | | | 07/06/21 1800 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 21 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-93 | | Collection Date: 05/06/2021 7:45 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000723 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1807 | 07/06/21 1807 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 151 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-94 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000515 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1809 | 07/06/21 1809 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 150 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-95 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000779 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1810 | 07/06/21 1810 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 30 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-96 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000701 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1812 | 07/06/21 1812 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 32 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-97 | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00520 | 0.015 AL | 0.000400 | mg/L | | 07/09/21 1432 | 07/09/21 1432 | EMB |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 31 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-98 | | Collection Date: 05/06/2021 7:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00107 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1837 | 07/06/21 1837 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 149 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-99 | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00113 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1839 | 07/06/21 1839 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 48 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AA | | Collection Date: 05/06/2021 7:50 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000861 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1840 | 07/06/21 1840 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 67 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AB | | Collection Date: 05/06/2021 6:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00196 | 0.015 AL | 0.000800 | mg/L | | 06/30/21 1544 | 07/01/21 1821 | EMB |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 68 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AC | | Collection Date: 05/06/2021 6:55 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000628 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1842 | 07/06/21 1842 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 85 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AD | | Collection Date: 05/06/2021 7:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000963 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1619 | 07/06/21 1619 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 87 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AE | | Collection Date: 05/06/2021 7:00 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00112 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1626 | 07/06/21 1626 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 42 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AF | | Collection Date: 05/06/2021 7:15 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000622 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1628 | 07/06/21 1628 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | |
|--------------------------------------|---|
| Client Sample ID: 44B | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:25 |
| Lab Sample ID: J1E1294-AG | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.000799 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1630 | 07/06/21 1630 | SEA |

| | |
|--------------------------------------|---|
| Client Sample ID: 40B | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:10 |
| Lab Sample ID: J1E1294-AH | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00267 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1637 | 07/06/21 1637 | SEA |

| | |
|--------------------------------------|---|
| Client Sample ID: 206 | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:26 |
| Lab Sample ID: J1E1294-AI | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1639 | 07/06/21 1639 | SEA |

| | |
|--------------------------------------|---|
| Client Sample ID: 42b | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:15 |
| Lab Sample ID: J1E1294-AJ | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00100 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1641 | 07/06/21 1641 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 44 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AK | | Collection Date: 05/06/2021 7:17 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00121 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1643 | 07/06/21 1643 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 205 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AL | | Collection Date: 05/06/2021 7:16 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1644 | 07/06/21 1644 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 35 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AM | | Collection Date: 05/06/2021 7:30 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00171 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1648 | 07/06/21 1648 | SEA |

| | | |
|----------------------------------|--------------------------------------|---|
| Client Sample ID: 207 | Sample Matrix: Drinking Water | Collected By: RF - Client |
| Lab Sample ID: J1E1294-AN | | Collection Date: 05/06/2021 7:35 |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|--|-----------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | <0.000400 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1650 | 07/06/21 1650 | SEA |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1E1294

| | |
|-------------------------------|----------------------------------|
| Client Sample ID: 204 | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:13 |
| Lab Sample ID: J1E1294-AO | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|-----------------------------------|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00637 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1655 | 07/06/21 1655 | SEA |

| | |
|-------------------------------|----------------------------------|
| Client Sample ID: 40 | Collected By: RF - Client |
| Sample Matrix: Drinking Water | Collection Date: 05/06/2021 7:11 |
| Lab Sample ID: J1E1294-AP | |

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

| Metals Total by ICPMS | Result | Limit(s) | RL | Units | Note | Prepared | Analyzed | Analyst |
|-----------------------------------|---------|----------|----------|-------|------|---------------|---------------|---------|
| Method: EPA 200.8, Rv. 5.4 (1994) | | | | | | | | |
| Lead | 0.00751 | 0.015 AL | 0.000400 | mg/L | | 07/06/21 1703 | 07/06/21 1703 | SEA |

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
10121
02-00257

New York State Department of Health
PA Department of Environmental Protection
PADEP Accreditation by Rule

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Chris Long
Director
Reported: 07/22/2021 17:43

Shannon River

Microbac Laboratories, Inc.

CHAIN OF CUSTODY


Samples must be returned on ice

MNY Workorder # _____

| Client Information | | Billing/Invoice: | Analysis Requested | | | | | Receiving Info (Lab Use Only) | |
|---------------------|---------------------|--|------------------------|---------|--|--|--|-------------------------------|--------|
| Name: | Jeff/Lew Boces | | Total Lead (EPA 200.8) | | | | | Ice: | YES NO |
| Address: | 20104 NYS Route 3 | | | | | | | Cooler: | YES NO |
| Contact: | Health/Safety Dept. | | | | | | | Sample Temp: | |
| Phone: | 315-779-7000 | | | | | | | Cooler Seal: | YES NO |
| Project: | | | | | | | | Pickup: | YES NO |
| Quote ID: | Lead Testing | PO#: | | | | | | Dropoff: | C W |
| Rush TAT Bus. Days: | <2 2-5 5-7 7-10 | Date Req.: | | | | | | Accepted? | YES NO |
| Carbon Copy: | Yes | | | | | | | Container Material | |
| Email Results: | Yes | rfilley@boces.com, fhauck@boces.com, lshaw@boces.com | | Plastic | | | | Container Size (in MI) | |
| Fax Results: | Yes | | | 250 ml | | | | Preservative | |

| Sample Information | | | | Matrix | Number of Containers for Analysis Requested | | | | | Comments/Field Data |
|--------------------|----------------------|------|------|--------|---|--|--|--|--|---------------------|
| | Description/Location | Date | Time | Type | | | | | | |
| 1 | 89 | 5/6 | 700 | DW | 1 | | | | | |
| 2 | 86 | | 700 | | | | | | | |
| 3 | 229 | | 655 | | | | | | | |
| 4 | 71 | | 655 | | | | | | | |
| 5 | 91 | | 700 | | | | | | | |
| 6 | 41B | | 710 | | | | | | | |
| 7 | 39 | | 655 | | | | | | | |
| 8 | 69 | | 655 | | | | | | | |
| 9 | 73 | | 650 | | | | | | | |
| 10 | 93 | | 702 | | | | | | | |
| 11 | 38 | | 710 | | | | | | | |
| 12 | 37 | | 710 | | | | | | | |
| 13 | 75 | | 650 | | | | | | | |
| 14 | 203 | | 706 | | | | | | | |
| 15 | 43B | | 717 | | | | | | | |
| 16 | 230 | | 700 | | | | | | | |
| 17 | 41 | | 612 | | | | | | | |
| 18 | 43A | | 717 | | | | | | | |
| 19 | 72 | | 655 | | | | | | | |
| 20 | 67 | | 655 | | | | | | | |

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks
 J 1 E 1 2 9 4



| | | |
|-----------------------------|-----------|----------|
| Print Name and Company | Date/Time | Comments |
| Sampled: <i>[Signature]</i> | 5/6/21 | |
| Received: | | |
| Received: | | |

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Salmon River

| Client Information | | | Billing/Invoice: | | Analysis Requested | | | | | | Receiving Info (Lab Use Only) | | |
|-----------------------------|----------------------|---------|--|-----------|---|----------|--|--|--|--|-------------------------------|------------------------|--------|
| Name: | Jeff/Lew Boces | | | | Total Lead (EPA 200.8) | | | | | | | Ice: | YES NO |
| Address: | 20104 NYS Route 3 | | | | | | | | | | | Cooler: | YES NO |
| Contact: | Health/Safety Dept. | | | | | | | | | | | Sample Temp: | |
| Phone: | 315-779-7000 | | | | | | | | | | | Cooler Seal: | YES NO |
| Project: | | | | | | | | | | | | Pickup: | YES NO |
| Quote ID: | Lead Testing | | PO#: | | | | | | | | | Dropoff: | C W |
| Rush TAT Bus. Days: | < 2-5 5-7 7-10 | | Date Req.: | | | | | | | | | Accepted? | YES NO |
| Carbon Copy: | Yes | | | | | | | | | | | Container Material | |
| Email Results: | Yes | | rfilley@boces.com, fhauck@boces.com, lshaw@boces.com | | | Plastic | | | | | | Container Size (in MI) | |
| Fax Results: | Yes | | | | | 250 ml | | | | | | Preservative | |
| | | | | | HNO3 | | | | | | | | |
| Sample Information | | | Matrix | | Number of Containers for Analysis Requested | | | | | | Comments/Field Data | | |
| | Description/Location | Date | Time | Type | | | | | | | | | |
| 1 | 51 | 5/16/21 | 6:35 | DW | 1 | | | | | | | | |
| 2 | 90 | | 7:00 | | | | | | | | | | |
| 3 | 70 | | 6:52 | | | | | | | | | | |
| 4 | 227 | | 6:45 | | | | | | | | | | |
| 5 | 220 | | 6:35 | | | | | | | | | | |
| 6 | 57A | | 6:30 | | | | | | | | | | |
| 7 | 221 | | 6:40 | | | | | | | | | | |
| 8 | 224 | | 6:50 | | | | | | | | | | |
| 9 | 74 | | 6:45 | | | | | | | | | | |
| 10 | 225 | | 6:45 | | | | | | | | | | |
| 11 | 76 | | 6:45 | | | | | | | | | | |
| 12 | 228 | | 6:45 | | | | | | | | | | |
| 13 | 77 | | 6:46 | | | | | | | | | | |
| 14 | 78 | | 6:46 | | | | | | | | | | |
| 15 | 79 | | 6:45 | | | | | | | | | | |
| 16 | 226 | | 6:40 | | | | | | | | | | |
| 17 | 80 | | 6:45 | | | | | | | | | | |
| 18 | 81 | | 6:45 | | | | | | | | | | |
| 19 | 52 | | 6:35 | | | | | | | | | | |
| 20 | 53 | | 6:35 | | | | | | | | | | |
| Print Name and Company | | | | Date/Time | | Comments | | | | | | | |
| Sampled: <i>[Signature]</i> | | | | 5/16/21 | | | | | | | | | |
| Received: | | | | | | | | | | | | | |
| Received: | | | | | | | | | | | | | |

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Salmon River

| Client Information | | | | Billing/Invoice: | | Analysis Requested | | | | | | Receiving Info (Lab Use Only) | | | | |
|---------------------------|----------------------|------|------|--|---|--|---------|----------|--|--|--|-------------------------------|--|------------------------|-----|----|
| Name: | Jeff/Lew Boces | | | | | Total Lead (EPA 200.8) | | | | | | | | Ice: | YES | NO |
| Address: | 20104 NYS Route 3 | | | | | | | | | | | | | Cooler: | YES | NO |
| Contact: | Health/Safety Dept. | | | | | | | | | | | | | Sample Temp: | | |
| Phone: | 315-779-7000 | | | | | | | | | | | | | Cooler Seal: | YES | NO |
| Project: | | | | | | | | | | | | | | Pickup: | YES | NO |
| Quote ID: | Lead Testing | | | PO#: | | | | | | | | | | Dropoff: | C | W |
| Rush TAT Bus. Days: | 2-5 5-7 7-10 | | | Date Req.: | | | | | | | | | | Accepted? | YES | NO |
| Carbon Copy: | Yes | | | | | | | | | | | | | Container Material | | |
| Email Results: | Yes | | | rfilley@boces.com, jhauck@boces.com, lshaw@boces.com | | | Plastic | | | | | | | Container Size (in MI) | | |
| Fax Results: | Yes | | | | | | 250 ml | | | | | | | Preservative | | |
| Sample Information | | | | Matrix | | Number of Containers for Analysis Requested | | | | | | Comments/Field Data | | | | |
| | Description/Location | Date | Time | Type | | | | | | | | | | | | |
| 1 | 2 | 5/6 | 605 | DW | 1 | | | | | | | | | | | |
| 2 | | | 610 | | | | | | | | | | | | | |
| 3 | | | 610 | | | | | | | | | | | | | |
| 4 | | | 610 | | | | | | | | | | | | | |
| 5 | | | 610 | | | | | | | | | | | | | |
| 6 | | | 610 | | | | | | | | | | | | | |
| 7 | | | 615 | | | | | | | | | | | | | |
| 8 | | | 610 | | | | | | | | | | | | | |
| 9 | | | 616 | | | | | | | | | | | | | |
| 10 | | | 626 | | | | | | | | | | | | | |
| 11 | | | 626 | | | | | | | | | | | | | |
| 12 | | | 627 | | | | | | | | | | | | | |
| 13 | | | 630 | | | | | | | | | | | | | |
| 14 | | | 625 | | | | | | | | | | | | | |
| 15 | | | 630 | | | | | | | | | | | | | |
| 16 | | | 625 | | | | | | | | | | | | | |
| 17 | | | 625 | | | | | | | | | | | | | |
| 18 | | | 625 | | | | | | | | | | | | | |
| 19 | | | 630 | | | | | | | | | | | | | |
| 20 | | | 641 | | | | | | | | | | | | | |
| Print Name and Company | | | | | | Date/Time | | Comments | | | | | | | | |
| Sampled: | | | | | | 5/6/21 | | | | | | | | | | |
| Received: | | | | | | | | | | | | | | | | |
| Received: | | | | | | | | | | | | | | | | |

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Salmon River

| Client Information | | Billing/Invoice: | Analysis Requested | | | | | | Receiving Info (Lab Use Only) | |
|---------------------|---------------------|--|------------------------|---------|--|--|--|--|-------------------------------|--------|
| Name: | Jeff/Lew Boces | | Total Lead (EPA 200.8) | | | | | | Ice: | YES NO |
| Address: | 20104 NYS Route 3 | | | | | | | | Cooler: | YES NO |
| Contact: | Health/Safety Dept. | | | | | | | | Sample Temp: | |
| Phone: | 315-779-7000 | | | | | | | | Cooler Seal: | YES NO |
| Project: | | | | | | | | | Pickup: | YES NO |
| Quote ID: | Lead Testing | PO#: | | | | | | | Dropoff: | C W |
| Rush TAT Bus. Days: | <2 2-5 5-7 7-10 | Date Req.: | | | | | | | Accepted? | YES NO |
| Carbon Copy: | Yes | | | | | | | | Container Material | |
| Email Results: | Yes | rfilley@boces.com, fhauck@boces.com, lshaw@boces.com | | Plastic | | | | | Container Size (in MI) | |
| Fax Results: | Yes | | | 250 ml | | | | | Preservative | |

| Sample Information | | | | Matrix | Number of Containers for Analysis Requested | | | | | | Comments/Field Data |
|--------------------|----------------------|------|------|--------|---|--|--|--|--|--|---------------------|
| | Description/Location | Date | Time | Type | | | | | | | |
| 1 | 133 | 5/16 | 755 | DW | 1 | | | | | | |
| 2 | 139 | | 755 | | | | | | | | |
| 3 | 138 | | 755 | | | | | | | | |
| 4 | 141 | | 750 | | | | | | | | |
| 5 | 142 | | 750 | | | | | | | | |
| 6 | 132 | | 755 | | | | | | | | |
| 7 | 144 | | 750 | | | | | | | | |
| 8 | 145 | | 750 | | | | | | | | |
| 9 | 165 | | 800 | | | | | | | | |
| 10 | 136 | | 758 | | | | | | | | |
| 11 | 130 | | 755 | | | | | | | | |
| 12 | 156 | | 800 | | | | | | | | |
| 13 | 153 | | 800 | | | | | | | | |
| 14 | 135 | | 750 | | | | | | | | |
| 15 | 157 | | 800 | | | | | | | | |
| 16 | 168 | | 800 | | | | | | | | |
| 17 | 154 | | 800 | | | | | | | | |
| 18 | 169 | | 800 | | | | | | | | |
| 19 | 166 | | 800 | | | | | | | | |
| 20 | 1 | | 805 | | | | | | | | |

| | | |
|-----------------------------|-----------|----------|
| Print Name and Company | Date/Time | Comments |
| Sampled: <i>[Signature]</i> | 5/16 | |
| Received: | | |
| Received: | | |

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and agree to the agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Salmon River

| Client Information | | | | Billing/Invoice: | | Analysis Requested | | | | | | Receiving Info (Lab Use Only) | | |
|---------------------|----------------------|------|------|--|---|------------------------|---------|--|--|--|---------------------|-------------------------------|------------------------|--------|
| Name: | Jeff/Lew Boces | | | | | Total Lead (EPA 200.8) | | | | | | | Ice: | YES NO |
| Address: | 20104 NYS Route 3 | | | | | | | | | | | | Cooler: | YES NO |
| Contact: | Health/Safety Dept. | | | | | | | | | | | | Sample Temp: | |
| Phone: | 315-779-7000 | | | | | | | | | | | | Cooler Seal: | YES NO |
| Project: | | | | | | | | | | | | | | |
| Quote ID: | Lead Testing | | | PO#: | | | | | | | | | Pickup: | YES NO |
| Rush TAT Bus. Days: | 2-5 5-7 7-10 | | | Date Req.: | | | | | | | | | Dropoff: | C W |
| Carbon Copy: | Yes | | | | | | | | | | | | Accepted? | YES NO |
| Email Results: | Yes | | | rfilley@boces.com, fhauck@boces.com, lshaw@boces.com | | | Plastic | | | | | | Container Material | |
| Fax Results: | Yes | | | | | | 250 ml | | | | | | Container Size (in MI) | |
| Sample Information | | | | Matrix | | HNO3 | | | | | | Preservative | | |
| | Description/Location | Date | Time | Matrix Type | Number of Containers for Analysis Requested | | | | | | Comments/Field Data | | | |
| 1 | 46 | 5/16 | 725 | DW | 1 | | | | | | | | | |
| 2 | 45 | | 725 | | | | | | | | | | | |
| 3 | 46B | | 725 | | | | | | | | | | | |
| 4 | 48B | | 725 | | | | | | | | | | | |
| 5 | 49A | | 730 | | | | | | | | | | | |
| 6 | 48 | | 725 | | | | | | | | | | | |
| 7 | 50B | | 730 | | | | | | | | | | | |
| 8 | 49B | | 730 | | | | | | | | | | | |
| 9 | 50A | | 730 | | | | | | | | | | | |
| 10 | 47 | | 730 | | | | | | | | | | | |
| 11 | 129 | | 725 | | | | | | | | | | | |
| 12 | 33 | | 740 | | | | | | | | | | | |
| 13 | 21 | | 745 | | | | | | | | | | | |
| 14 | 151 | | 750 | | | | | | | | | | | |
| 15 | 150 | | 750 | | | | | | | | | | | |
| 16 | 30 | | 730 | | | | | | | | | | | |
| 17 | 32 | | 730 | | | | | | | | | | | |
| 18 | 31 | | 735 | | | | | | | | | | | |
| 19 | 149 | | 750 | | | | | | | | | | | |
| 20 | 48 | | 750 | | | | | | | | | | | |

Page 34 of 35

| | | |
|-----------------------------|-----------|----------|
| Print Name and Company | Date/Time | Comments |
| Sampled: <i>[Signature]</i> | | |
| Received: | | |
| Received: | | |

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder # _____

Salmon River

| Client Information | | | | Billing/Invoice: | | Analysis Requested | | | | | | Receiving Info (Lab Use Only) | | | |
|-----------------------------|---------------------|------|------|--|--|---|--|--|--|--|--|-------------------------------|------------------------|--------------|--------|
| Name: | Jeff/Lew Boces | | | | | Total Lead (EPA 200.8) | | | | | | | Ice: | YES NO | |
| Address: | 20104 NYS Route 3 | | | | | | | | | | | | | Cooler: | YES NO |
| Contact: | Health/Safety Dept. | | | | | | | | | | | | | Sample Temp: | |
| Phone: | 315-779-7000 | | | | | | | | | | | | | Cooler Seal: | YES NO |
| Project: | | | | | | | | | | | | | | Pickup: | YES NO |
| Quote ID: | Lead Testing | | | PO#: | | | | | | | | | | Dropoff: | C W |
| Rush TAT Bus. Days: | <2 2-5 5-7 7-10 | | | Date Req.: | | | | | | | | | | Accepted? | YES NO |
| Carbon Copy: | Yes | | | | | Plastic | | | | | | | Container Material | | |
| Email Results: | Yes | | | rfilley@boces.com, fhauck@boces.com, lshaw@boces.com | | 250 ml | | | | | | | Container Size (in MI) | | |
| Fax Results: | Yes | | | | | HNO3 | | | | | | | Preservative | | |
| Sample Information | | | | Matrix | | Number of Containers for Analysis Requested | | | | | | Comments/Field Data | | | |
| Description/Location | Date | Time | Type | | | | | | | | | | | | |
| 1 | 6/7 | 6:55 | DW | 1 | | | | | | | | | | | |
| 2 | 6/8 | 6:55 | | | | | | | | | | | | | |
| 3 | 8/5 | 7:00 | | | | | | | | | | | | | |
| 4 | 8/7 | 7:00 | | | | | | | | | | | | | |
| 5 | 4/2 | 7:15 | | | | | | | | | | | | | |
| 6 | 4/4 B | 7:25 | | | | | | | | | | | | | |
| 7 | 4/0 B | 7:10 | | | | | | | | | | | | | |
| 8 | 2/0 6 | 7:26 | | | | | | | | | | | | | |
| 9 | 4/2 B | 7:15 | | | | | | | | | | | | | |
| 10 | 4/4 | 7:17 | | | | | | | | | | | | | |
| 11 | 2/0 5 | 7:16 | | | | | | | | | | | | | |
| 12 | 3/5 | 7:30 | | | | | | | | | | | | | |
| 13 | 2/0 7 | 7:35 | | | | | | | | | | | | | |
| 14 | 2/0 4 | 7:13 | | | | | | | | | | | | | |
| 15 | 4/0 | 7:11 | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | |
| 17 | | | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | | | |
| 20 | | | | | | | | | | | | | | | |
| Print Name and Company | | | | Date/Time | | Comments | | | | | | | | | |
| Sampled: <i>[Signature]</i> | | | | 5/6 | | | | | | | | | | | |
| Received: | | | | | | | | | | | | | | | |
| Received: | | | | | | | | | | | | | | | |

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to subcontract and are in agreement with this action.